



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Madison Elementary School
43 Learners Lane
Madison, ME 04950

Date Printed: 11/17/2022
Work Order #: 2211-01204
Client Job #: 911
Date Received: 11/04/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

Nashoba Analytical:
Identified by MA in the Analyst Column
31A Willow Road, Ayer, MA 01432
www.nashobaanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 11/17/2022
CLIENT NAME: Madison Elementary School

CLIENT ADDRESS: 43 Learners Lane
 Madison, ME 04950

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/04/2022 02:50PM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 22° CELSIUS
CLIENT JOB #: 911

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-01204-001	Nurses Station	I	OT	11/02/2022 06:09AM	<1	ppb			JLR-NH	11/10/2022 02:18PM
2211-01204-002	Room 106	I	OT	11/02/2022 06:08AM	<1	ppb			JLR-NH	11/10/2022 02:30PM
2211-01204-003	Room 109	I	OT	11/02/2022 06:08AM	3.8	ppb			JLR-NH	11/10/2022 02:33PM
2211-01204-004	Room 105	I	OT	11/02/2022 06:06AM	1.1	ppb			JLR-NH	11/16/2022 03:03PM
2211-01204-005	Room 108	I	OT	11/02/2022 06:06AM	<1	ppb			JLR-NH	11/10/2022 02:44PM
2211-01204-006	Room 110	I	OT	11/02/2022 06:05AM	<1	ppb			JLR-NH	11/10/2022 02:47PM
2211-01204-007	Room 112	I	DWF	11/02/2022 06:24AM	<1	ppb			JLR-NH	11/10/2022 02:50PM
2211-01204-008	Room 114	I	OT	11/02/2022 06:24AM	<1	ppb			JLR-NH	11/10/2022 02:53PM
2211-01204-009	Room 131	I	OT	11/02/2022 06:23AM	<1	ppb			JLR-NH	11/10/2022 02:56PM
2211-01204-010	Room 129	I	OT	11/02/2022 06:20AM	<1	ppb			JLR-NH	11/10/2022 02:59PM
2211-01204-011	Room 124	I	OT	11/02/2022 06:15AM	<1	ppb			JLR-NH	11/10/2022 03:07PM
2211-01204-012	Room 125	I	OT	11/02/2022 06:13AM	<1	ppb			JLR-NH	11/10/2022 03:10PM
2211-01204-013	Room 122	I	OT	11/02/2022 06:12AM	<1	ppb			JLR-NH	11/10/2022 03:13PM
2211-01204-014	Room 120	I	OT	11/02/2022 06:11AM	<1	ppb			JLR-NH	11/10/2022 03:16PM
2211-01204-015	Room 123	I	OT	11/02/2022 06:11AM	<1	ppb			JLR-NH	11/10/2022 03:25PM
2211-01204-016	Room 121	I	OT	11/02/2022 06:11AM	<1	ppb			JLR-NH	11/10/2022 03:28PM
2211-01204-017	Room 102	I	OT	11/02/2022 06:10AM	<1	ppb			JLR-NH	11/10/2022 03:31PM
2211-01204-018	Room 103	I	OT	11/02/2022 06:00AM	<1	ppb			JLR-NH	11/10/2022 03:34PM
2211-01204-019	Back Lob A	I	DWF	11/02/2022 06:01AM	<1	ppb			JLR-NH	11/10/2022 03:45PM
2211-01204-020	Back Lob B	I	DWF	11/02/2022 06:28AM	<1	ppb			JLR-NH	11/10/2022 03:48PM
2211-01204-021	3Bay Sink	I	KF	11/02/2022 06:32AM	1.9	ppb			JLR-NH	11/10/2022 03:51PM
2211-01204-022	Hand Sk A	I	KF	11/02/2022 06:31AM	1.1	ppb			JLR-NH	11/10/2022 03:54PM
2211-01204-023	Hand Sk B	I	KF	11/02/2022 06:31AM	7.3	ppb			JLR-NH	11/10/2022 03:57PM
2211-01204-024	Dsh Wsher	I	KF	11/02/2022 06:31AM	<1	ppb			JLR-NH	11/10/2022 04:00PM
2211-01204-025	Boiler	I	KF	11/02/2022 06:30AM	1.1	ppb			JLR-NH	11/10/2022 04:09PM
2211-01204-026	Veg Sk	I	KF	11/02/2022 06:30AM	<1	ppb			JLR-NH	11/10/2022 04:12PM

Rebecca L. Labranche
 Laboratory Director