



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 12/06/2022
CLIENT NAME: Madison Junior High School
CLIENT ADDRESS: 205 Main Street
 Madison, ME 04950

| Legend | |
|-------------------|--|
| Lead Above 4 ppb | |
| Lead Above 15 ppb | |

METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

DATE AND TIME RECEIVED: 11/22/2022 10:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 16° CELSIUS
CLIENT JOB #: 910

| Sample ID # | Location | Sample Type | Outlet Type | Date - Time Water Sampled | Result | Test Units | Pass /Fail | DQ Flag | Analyst | Date - Time Analyzed |
|----------------|----------|-------------|-------------|---------------------------|--------|------------|------------|---------|---------|----------------------|
| 2211-04469-001 | Room 106 | C | OT | 11/21/2022 06:50AM | 2.5 | ppb | | | JLR-NH | 12/05/2022 05:24PM |
| 2211-04469-002 | Room 203 | C | OT | 11/21/2022 06:40AM | 152 | ppb | | | JLR-NH | 12/05/2022 05:27PM |
| 2211-04469-003 | Room 207 | C | OT | 11/21/2022 06:44AM | 2.1 | ppb | | | JLR-NH | 12/05/2022 05:36PM |
| 2211-04469-004 | Room 209 | C | OT | 11/21/2022 06:37AM | 6.1 | ppb | | | JLR-NH | 12/05/2022 05:39PM |
| 2211-04469-005 | Room 213 | C | OT | 11/21/2022 06:35AM | 25.4 | ppb | | | JLR-NH | 12/05/2022 05:42PM |
| 2211-04469-006 | Room 218 | C | OT | 11/21/2022 06:30AM | 1.4 | ppb | | | JLR-NH | 12/05/2022 05:45PM |

Rebecca L. Labranche
 Laboratory Director