



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

**Madison Junior High School**  
205 Main Street  
Madison, ME 04950

**Date Printed:** 11/11/2022  
**Work Order #:** 2211-01123  
**Client Job #:** 910  
**Date Received:** 11/04/2022  
**Sample collected in:** Maine

**Attached please find results for the analysis of the samples received on the date referenced above.**

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

**Nashoba Analytical:**  
*Identified by MA in the Analyst Column*  
31A Willow Road, Ayer, MA 01432  
[www.nashobaanalytical.com](http://www.nashobaanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- DF: "Dilution factor" means the ratio of the volume of the sample to the volume of the final (dilute) solution.
- MDL: "Minimum Detection Limit" means the minimum result which can be reliably discriminated from a blank with a predetermined confidence level.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 11/11/2022  
**CLIENT NAME:** Madison Junior High School

**CLIENT ADDRESS:** 205 Main Street  
 Madison, ME 04950

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 11/04/2022 02:50PM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 19° CELSIUS  
**CLIENT JOB #:** 910

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-01123-001	KVMPA Kitchen Dish washing sink	I	KF	10/21/2022 07:30AM	<1	ppb			JLR-NH	11/09/2022 09:37PM
2211-01123-002	KVMPA Handwashing sink	I	KF	10/21/2022 07:30AM	<1	ppb			JLR-NH	11/09/2022 09:40PM
2211-01123-003	Room 231	I	DWF	10/24/2022 10:50AM	2.7	ppb			JLR-NH	11/09/2022 09:43PM
2211-01123-004	Room 149	I	OT	10/25/2022 07:30AM	<1	ppb			JLR-NH	11/09/2022 09:46PM
2211-01123-005	Room 152	I	OT	10/26/2022 09:05AM	<1	ppb			JLR-NH	11/09/2022 09:49PM
2211-01123-006	Cafe drink stat	I	DWF	10/24/2022 09:02AM	<1	ppb			JLR-NH	11/09/2022 09:52PM
2211-01123-007	Kitchen 3 bay sink	I	KF	10/24/2022 09:02AM	1.0	ppb			JLR-NH	11/09/2022 09:55PM
2211-01123-008	Kitchen prep sink	I	KF	10/24/2022 09:00AM	<1	ppb			JLR-NH	11/09/2022 09:58PM
2211-01123-009	Kitchen handwashing sink	I	KF	10/24/2022 09:02AM	1.2	ppb			JLR-NH	11/09/2022 10:01PM
2211-01123-010	Kitchen dish room	I	KF	10/24/2022 09:01AM	<1	ppb			JLR-NH	11/09/2022 10:15PM
2211-01123-011	Kitchen steam kettle	I	KF	10/24/2022 09:01AM	1.1	ppb			JLR-NH	11/09/2022 10:18PM
2211-01123-012	Room 005	I	DWF	10/24/2022 10:00AM	<1	ppb			JLR-NH	11/09/2022 10:21PM
2211-01123-013	Room 119A	I	OT	10/24/2022 10:59AM	2.2	ppb			JLR-NH	11/09/2022 10:24PM
2211-01123-014	Room 113	I	DWF	10/24/2022 11:00AM	<1	ppb			JLR-NH	11/09/2022 10:27PM
2211-01123-015	Room 111	I	DWF	10/24/2022 10:37AM	<1	ppb			JLR-NH	11/09/2022 10:30PM
2211-01123-016	Room 106	I	OT	10/24/2022 10:55AM	24.3	ppb			JLR-NH	11/09/2022 10:33PM
2211-01123-017	Room 104 A	I	OT	10/25/2022 07:30AM	<1	ppb			JLR-NH	11/09/2022 10:36PM
2211-01123-018	Room 104 B	I	OT	10/25/2022 07:30AM	<1	ppb			JLR-NH	11/09/2022 10:48PM
2211-01123-019	Room 104 C	I	OT	10/25/2022 07:30AM	<1	ppb			JLR-NH	11/09/2022 10:51PM
2211-01123-020	Room 203	I	OT	10/24/2022 10:45AM	473	ppb			JLR-NH	11/09/2022 10:59PM
2211-01123-021	Room 204	I	OT	10/24/2022 10:45AM	1.1	ppb			JLR-NH	11/09/2022 11:02PM
2211-01123-022	Room 207	I	OT	10/24/2022 10:40AM	13.6	ppb			JLR-NH	11/09/2022 11:05PM
2211-01123-023	Room 209	I	OT	10/24/2022 10:41AM	6.3	ppb			JLR-NH	11/09/2022 11:08PM
2211-01123-024	Room 211	I	OT	10/24/2022 06:53AM	4.0	ppb			JLR-NH	11/09/2022 11:11PM
2211-01123-025	2nd Floor Boys	I	DWF	10/26/2022 09:00AM	<1	ppb			JLR-NH	11/09/2022 11:14PM
2211-01123-026	2nd Floor Girls	I	DWF	10/26/2022 09:00AM	<1	ppb			JLR-NH	11/09/2022 11:23PM

Rebecca L. Labranche  
 Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 11/11/2022  
**CLIENT NAME:** Madison Junior High School  
**CLIENT ADDRESS:** 205 Main Street  
 Madison, ME 04950

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 11/04/2022 02:50PM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 19° CELSIUS  
**CLIENT JOB #:** 910

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2211-01123-027	Room 213	I	OT	10/24/2022 10:51AM	9.9	ppb			JLR-NH	11/09/2022 11:26PM
2211-01123-028	Room 216	I	OT	10/24/2022 10:46AM	<1	ppb			JLR-NH	11/09/2022 11:29PM
2211-01123-029	Room 217	I	OT	10/24/2022 10:46AM	2.1	ppb			JLR-NH	11/09/2022 11:32PM
2211-01123-030	Room 218	I	OT	10/24/2022 10:41AM	11.0	ppb			JLR-NH	11/10/2022 01:17PM
2211-01123-031	Cafeteria Ice Machine	I	KF	10/26/2022 09:05AM	<1	ppb			JLR-NH	11/10/2022 01:19PM

Rebecca L. Labranche  
 Laboratory Director